

Drinking-Water Systems Regulation O. Reg. 170/03

Part III Form 2

Section 11. ANNUAL REPORT.

Drinking-Water System Number:	260096811
Drinking-Water System Name:	Gilford Well Water
Drinking-Water System Owner:	Community Living association for south Simcoe
Drinking-Water System Category:	SNMYR
Period being reported:	April 5, 2024 to March 7, 2025

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/></p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/></p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; min-height: 100px;"> <p>233 Church street south Alliston, on, L9R 2B7</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <div style="border: 1px solid black; width: 100px; text-align: center; padding: 2px;">1</div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> </p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; width: 100px; text-align: center; padding: 2px;">3</div></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> </p>
--	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
Gilford Well Water	260096811

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
 Yes No

Drinking-Water Systems Regulation O. Reg. 170/03

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

Gilford residence DWS is a small non-municipal non residential system, serving a designated facility. Water is supplied to Gilford residence from one drilled ground water well. The equipment is located in the basement of the house and comprises of the following equipment. One 250mm long cartridge filter housing equipped with a 5 micron cartridge filter. A treated water sample tap

List all water treatment chemicals used over this reporting period

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Replaced UV lamp and sleeve and 5 micron filter every 3 months

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
Jan 9, 2025	sodium	129	mg/L	resample	Jan 27 2025

Drinking-Water Systems Regulation O. Reg. 170/03

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	12	0-0	0-0		
Treated	12	0-0	0-0		
Distribution	12	0 - 0	0-0		

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity		
Chlorine		
Fluoride (If the DWS provides fluoridation)		

NOTE: For continuous monitors use 8760 as the number of samples.

NOTE: Record the unit of measure if it is not milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				
Barium	Jan 6 2025	<0.001	mg/L	
Boron	Jan 6 2025	0.035	mg/L	
Cadmium	Jan 6 2025	0.000067	mg/L	
Chromium	Jan 6 2025	<0.0010	mg/L	
Lead				
Mercury	Jan 6 2025	<0.00002	mg/L	
Selenium	Jan 6 2025	<0.001	mg/L	
Sodium	Jan 6 2025	129	mg/L	109
Uranium	Jan 6 2025	<0.00005	mg/L	
Fluoride				

Drinking-Water Systems Regulation O. Reg. 170/03

Nitrite	April to March	0	mg/l	
Nitrate	April to March	0	mg/l	

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	Jan 6 2025	<0.3	ug/L	
Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites	Jan 6 2025	<0.5	ug/L	
Azinphos-methyl	Jan 6 2025	<1	ug/L	
Bendiocarb				
Benzene	Jan 6 2025	<0.5	ug/L	
Benzo(a)pyrene	Jan 6 2025	<0.006	ug/L	
Bromoxynil	Jan 6 2025	<0.5	ug/L	
Carbaryl	Jan 6 2025	<3	ug/L	
Carbofuran	Jan 6 2025	<1	ug/L	
Carbon Tetrachloride	Jan 6 2025	<0.2	ug/L	
Chlordane (Total)				
Chlorpyrifos	Jan 6 2025	<0.5	ug/L	
Cyanazine				
Diazinon	Jan 6 2025	<1	ug/L	
Dicamba				
1,2-Dichlorobenzene	Jan 6 2025	<0.5	ug/L	
1,4-Dichlorobenzene	Jan 6 2025	<0.5	ug/L	
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane	Jan 6 2025	<0.5	ug/L	
1,1-Dichloroethylene (vinylidene chloride)	Jan 6 2025	<0.5	ug/L	
Dichloromethane				
2-4 Dichlorophenol	Jan 6 2025	<0.2	ug/L	
2,4-Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl				
Dimethoate	Jan 6 2025	<1	ug/L	
Dinoseb				
Diquat				
Diuron	Jan 6 2025	<5	ug/L	
Glyphosate				
Heptachlor + Heptachlor Epoxide				
Lindane (Total)				
Malathion	Jan 6 2025	<5	ug/L	
Methoxychlor				
Metolachlor				

Drinking-Water Systems Regulation O. Reg. 170/03

Metribuzin				
Monochlorobenzene				
Paraquat				
Parathion				
Pentachlorophenol	Jan 6 2025	<0.2	ug/L	
Phorate	Jan 6 2025	<0.3	ug/L	
Picloram				
Polychlorinated Biphenyls(PCB)				
Prometryne	Jan 6 2025	<0.1	ug/L	
Simazine	Jan 6 2025	<0.5	ug/L	
THM (NOTE: show latest annual average)				
Temephos				
Terbufos	Jan 6 2025	<0.5	ug/L	
Tetrachloroethylene	Jan 6 2025	<0.5	ug/L	
2,3,4,6-Tetrachlorophenol	Jan 6 2025	<0.2	ug/L	
Triallate	Jan 6 2025	<10	ug/L	
Trichloroethylene	Jan 6 2025	<0.5	ug/L	
2,4,6-Trichlorophenol	Jan 6 2025	<0.2	ug/L	
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)				
Trifluralin	Jan 6 2025	<0.5	ug/L	
Vinyl Chloride	Jan 6 2025	<0.5	ug/L	

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)